



Chhatrapati Sambhajanagar. Municipal Corporation
FIRE BRIGADE
TELEPHONE NO-2334000-40FAX No-2331444

Outward No:CSMC/FIRE/1278/2026

Date 6 / 02 /2026

To,
Principal, D.K.M.M. Homeopathy,
Medical Hospital Building,
CTS No. 1956, At. Pahadsingpura,
Dist. Chhatrapati Sambhajanagar.

Sub;- Final Fire Noc is issued to the D.K.M.M. Homeopathy, Medical Hospital Building, CTS No. 1956, At. Pahadsingpura, Dist. Chhatrapati Sambhajanagar.

Ref:- 1) Your Letter date 13/12/2025 2) Provisional Noc on date 10/01/2026
3) Your Letter date 06/02/2026 4) CFO Inspection on date 06/02/2026

With Reference to the above subject Final Fire Noc is issued to the D.K.M.M. Homeopathy, Medical Hospital Building, CTS No. 1956, At. Pahadsingpura, Dist. Chhatrapati Sambhajanagar. Plot area is 32284.00 Sq.mtr.


Owner has paid Final Noc fees 10000/- in Fire Brigade in Receipt No. 13466 on date 06 /02 /2026.

S.No	Building	Height	Building	Floor	Area of Plot	Builtup Area	Fire Fund	Noc Fees
1	Medical Hospital Building	06.00	01	G+1	32284.00 Sq.mtr	1654.352Sq.mtr Per Sq.mtr 121/- 200176.59	200178	10000
							200178	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to **Medical Hospital Building** is provided.

1. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Underground Water tank 50000 Ltr & Main Fire Pump-5 HP-01 No, of Suitable capacity for building is Provided.
3. 01 Nos. Fire service inlet 2 way incoming is provided.
4. 01 Nos. Hydrant points all around the building with fire Hose Pipe-01 Nos/ Branch-01 Nos is provided.
5. 01 Nos.Wet Riser having outlet on all floors with Hose Pipe-03 Nos / Branch-02 Nos is Provided.
6. 02 Nos Hose Reel of 100 feet on all outlets is provided.
7. Fire Extinguisher of / ABC-06 Kg-10 Nos of Suitable Capacity / quantity is provided.
8. Smoke Detector System -10 Nos. is Provided.
9. This Certificate shall be treated valid for a period of one year from, the date of issue up to Final Fire Noc
- 11 Fire Noc must be Renewaled on each year.

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject Final Fire Noc is issued to the Principal, D.K.M.M. Homeopathy, Medical Hospital Building, CTS No. 1956, At. Pahadsingpura, Dist. Chhatrapati Sambhajanagar.


Chief Fire Officer
Fire Brigade, Municipal Corporation
Chhatrapati Sambhajanagar.

Copy to:- C S T.P, Chhatrapati Sanbhajanagar